



Facility for Low Carbon Technology Deployment



Encon Thermal Engineers Private Limited
(Regenerative Burner System)

FLCTD 2019 Grant Winner- WHR

**Measurement and Verification Report of
Technology**

Demonstration and Validation

Prepared By



Confederation of Indian Industry

CII – Sohrabji Godrej Green Business Centre

Survey No. 64, Kothaguda Post, NearHITEC City

Hyderabad 500084

November 2020

Disclaimer

© 2020

This measurement and verification report is part of the United Nations Industrial Development Organization (UNIDO), Bureau of Energy Efficiency (BEE), Government of India and CII-Sohrabji Godrej Green Business Center's (CII-SGGBC) effort with the support of Global Environment Facility (GEF); to establish the efficacy of innovation that will lend credibility of the innovation to seek financing for scale-up.

The benefits estimated by CII-SGGBC were based on data gathered from field trials at different locations. Since this solution/product is not yet commercially available, the return on investment (ROI) has not been estimated.

PREFACE

The main objective of the “Facility for Low Carbon Technology Deployment” (FLCTD) is to facilitate deployment and scaling up of low-carbon technologies in India that can address technology gaps in mitigating climate change and promote the use of clean energy applications in selected sectors. The main function of the ‘Facility*’ is to identify high-impact challenges that if solved have potential for large-scale carbon emission reductions. The project aims to locate and link the critical connections between the stakeholders – those who are aware of the high-impact challenge and those with the technical expertise to provide solutions – to solve problems identified by experts.

FLCTD project conducts annual innovation challenges to solicit applications from innovative technologies under three technology verticals, namely: Waste Heat Recovery, Space Conditioning and, Pump and Motor Systems. Winners of the innovation challenge are selected through a rigorous screening process by an expert panel. Each winner receives:

- Grant award up to USD 50,000 for winning technology demonstration at multiple locations.
- Performance verification to establish the efficacy of innovative technology in field working conditions.
- Recognition from Bureau of Energy Efficiency and UNIDO.

The grant award enables the deployment and validation of the innovations at field locations; typically, industries/firms willing for pilot demonstration where the technology is periodically monitored, and performance validated. The technology verification process is expected to validate the efficacy of innovation and will lend credibility to the innovation for replication.

To achieve these objectives, the project has built a Technology Verification process for all FLCTD grant winning innovations, in consultation with the implementation partner, the Confederation of Indian Industry - Sohrabji Godrej Green Business Centre, Hyderabad (hereinafter CII-SGGBC). The CII-SGGBC provides implementation support to the project, especially in outreach efforts, providing connects with industries for technology demonstration, and validation of winning technologies in actual field conditions.

**The BEE, the PMU-UNIDO and the Expert Panel is referred to as “The Facility” henceforth.*

CONTENTS

SELECTION UNDER FLCTD INNOVATION CHALLENGE	6
ABOUT THE COMPANY	6
DETAILS OF THE INNOVATION.....	7
DESIGN OBJECTIVES OF THE INNOVATION	7
1. Scope of Demonstration under FLCTD	8
2. Details of the Regenerative Burners	9
3. Technology Measurement and Verification.....	11
4. Findings.....	13
5. Conclusion and Replication Potential.....	19
6. Annexure	23
Annexure A : Assumptions made in the report.....	23
Annexure B : Major Formulae used in the report	23
Annexure C : Refernces & Reports Referred for Estimating Replication Potential.....	24
Annexure D : P&I diagram of the existing setup	25
Annexure E : block diagram considering 90 sec reversal cycle for mode a & mode b	26
Annexure F : P&I diagram Multi Bore Orifice plate assembly.....	27
Annexure G : Orifice plate BORE calculation as per iso-5167 for air	28
Annexure H : Orifice plate BORE calculation as per iso-5167 for lpg.....	29
Annexure I: Terms of Reference of Innovation Challenge	30

LIST OF TABLES

Table 1: Pilot Site Details	8
Table 2: Pilot Project details	10
Table 3: Sample Data Batch -1 & 2	13
Table 4: Steady State Parameters at 60 Sec Cycle.....	14
Table 5: Heat Gain in 60 Sec Cycle	14
Table 6: Steady State Parameters at 90 Sec Cycle.....	15
Table 7: Heat Gain in 90 Sec Cycle	15
Table 8: Steady State Parameters at 120 Sec Cycle.....	16
Table 9: Heat Gain in 120 Sec Cycle	16
Table 10: Steady State Parameters at 150 Sec Cycle.....	17
Table 11: Heat Gain in 150 Sec Cycle.....	17
Table 12: Summary of Results	19
Table 14: Anticipated replication potential across different sectors	22

LIST OF FIGURES

Figure 1: Block Diagram of Working Principle	9
Figure 2 – Regenerative Burner System	11
Figure 3: Furnace with Regenerative Burners on either ends.....	11
Figure 4 Plaque on Furnace with Regenerative Burners	20

LIST OF ABBREVIATIONS

BEE	Bureau of Energy Efficiency
CII	Confederation of Indian Industry
CO ₂	Carbon dioxide
GHG	Greenhouse Gas
INR	Indian Rupees
IR	Infra-Red
M&V	Measurement and Verification
TOE	Tonne of Oil Equivalent
UNIDO	United Nations Industrial Development Organization
WHR	Waste Heat Recovery

UNIT OF MEASUREMENTS

°C	Degree Celsius
kCal	kilo Calorie
kVA	Apparent Power
kW	Kilo Watt (Active Power)
MT	Million Tonne
SCM	Standard Cubic Meter

TECHNOLOGY VERIFICATION REPORT

SELECTION UNDER FLCTD INNOVATION CHALLENGE

In 2019 the 2nd Annual Innovation Challenge under the FLCTD project was announced in 3rd week of May 2019. The Terms of Reference of the Waste Heat Recovery innovation challenge is attached in Annexure A. The application submission was closed on 18th August 2019, and 34 applications were received in the Waste Heat Recovery technology vertical. The review of applications by the expert panel members was held on 4th September, 2019 in which nine applications were shortlisted for final presentation. The final presentations by the shortlisted applicants under the was held at the UNIDO project office on 25th September 2019. Based on merit of innovations and replication potential, seven firms were selected by an expert panel for receiving financial assistance from FLCTD project. These are:

1. M/s Aspiration Energy Pvt Ltd
2. M/s Centre for Energy Environment and Productivity
3. M/s ENCON Thermal Engineers Pvt Ltd
4. M/s Forbes Marshall Pvt Ltd
5. M/s Promethean Energy Pvt Ltd
6. M/s Opel Energy Systems Pvt Ltd
7. M/s Oorja Energy Engineering Services Hyderabad Pvt Ltd

ABOUT THE COMPANY

ENCON Thermal Engineers was established during the energy crisis of 1978 in INDIA. The name was coined from the phrase "Energy Conservation & Conversion". After establishing the credentials in heat recovery systems and energy management system, ENCON started manufacturing furnaces and its allied equipment. It is managed by qualified Engineers & technocrats who are well- versed in designing, manufacturing, installation and commissioning of fuel-efficient systems. ENCON Thermal Engineers has been involved in a lot of research and development programs and has developed a lot of heating technologies, Over the last 30 years, they have been pioneers in introducing new and better energy efficient and conservation technologies in the country. The technologies developed and introduced by them, have been successfully running in the public sector and the private sector of the country and outside the country.

DETAILS OF THE INNOVATION

- **Name of the innovation:** Regenerative Burner System.
- **Areas of application:** Aluminium Melting Furnaces, Forging Furnaces, Glass Furnaces, Heat Treatment Furnaces, Kilns for Ceramic, Ladle Preheaters, Soaking Pits, Steel Reheating furnaces.

DESIGN OBJECTIVES OF THE INNOVATION

Regenerative and Recuperative burners optimise the energy-efficiency of the process by to using the heat released by furnace exhaust which if not utilised would go waste. Typically, In Regenerative burners heat from the flue gases are stored in the Regenerator Box. Regenerative Burners work in pairs, where in one burner uses the energy stored in the Regenerator Box to preheat the combustion air and the Regenerator Box of the Second burner act as a reservoir where the heat from the flue gas is stored. This process is reversed after a set interval of time. The objective of the innovation is to successfully demonstrate the working of Regenerative Burner in the test furnace and to determine the percentage heat gain by the combustion air and effectiveness of the Waste Heat Recovery system. Once the results are satisfactory, this technology can be replicated in various industries across the country.

1. SCOPE OF DEMONSTRATION UNDER FLCTD

The objective of the innovation is to maximise the Energy recovery from the high temperature flue gases and use this energy to increase the temperature of combustion air. This will lead to reduction in fuel Consumption and increase in overall efficiency of the process. Each Regenerative Burner System consists of the following main parts

- Burner with Nozzles and Burner Block
- Regenerator Box with Media Balls
- LPG/NG Pilot burner with UV sensor and Ignition Transformer
- Gas & Combustion air Pressure and Flow Regulation System
- Blower for Combustion Air and Flue Gases

Key aspects taken into consideration for measuring the efficacy of the innovation:

- Type of furnace.
- Rated Capacity of Furnace (for each burner).
- Rated Combustion Blower Flow.
- Type of Fuel used/Fuel Calorific Value.
- Type of Media inside WHR (Regenerative units).
- Quantity and Weight of Media inside WHR (Regenerative units).
- Furnace Temperature.
- Combustion air; Inlet & Outlet temperature (across Ceramic media box).
- Flue gas: Inlet & Outlet Temperature (across Ceramic media box).
- Fuel Consumption (based on totalizer).
- Combustion Air Flow.

The details of the demonstration site are given below:

Table 1: Pilot Site Details

Demonstration Details	
Name of the pilot/project site	M/s ENCON Thermal Engineers Private Limited
Address of the pilot/project site	53 KM Stone, Delhi - Mathura Road, Vill. Baghola, Distt. Palwal - 121 102 Haryana (India)
Name of the contact person at Site	Mr Puneet Mahendra (Director)
Contact details (Tel./Email)	+91 9971499079, pm@encon.co.in
Type of industry for site demonstration	Industry – Aluminium & Steel furnaces

2. DETAILS OF THE REGENERATIVE BURNERS

Regenerative burner technology is developed to maximise energy recovery from the flue gas generated during direct heating process, this recovered energy is used for preheating the incoming combustion air. Preheating of combustion air increased the efficiency of the process and reduced the fuel required for heating. Regenerative burners operate in pairs and work on the principle of short-term heat storage using ceramic balls in the Regenerator Box of the burner. Thus, eliminating the need of conventional recuperator. The regenerative burner has two type of lances:

1. Flame less (above 750Deg C for low Nox)- The NOx emissions can reduce between 20 to 80% depending on the process temperature and parameters between the normal and Low NOx flameless mode
2. Normal flame

The typical operating principle is explained below:

In Mode A, Burner A fires and Burner B act as a Regenerator or Heat Sink, the flue gas is sucked by Burner B and the flue gas travels through the Regenerator Box of Burner B to the chimney, The Media box is filled with Ceramic balls which absorbs up to 85% of the heat of the flue gasses.

In Mode B, the process is reversed and Burner A act as the regenerator and Burner B fires. In this case

combustion air passes through the hot media and can achieve a combustion air temperature in the range of 416 to 497°C, when the process temperature is in the range of 898 to 904°C. The compact and cost-effective system design can make it ideal for retrofit/upgrade projects for energy efficiency, productivity and/or CO₂ emission control in a variety of industrial heating applications.




Figure 1: Block Diagram of Working Principle

The pilot demonstration of the system was done in a “closed box test furnace” at the factory of Encon Thermal Engineers Pvt Ltd in Vill- Baghola, Tehsil-Palwal, Haryana. And the initial site visits were made on February 2020, for understanding the progress of installation and commissioning of the furnace. The detailed parameters monitored and observed during site visit at the pilot site are given below:

Table 2: Pilot Project details

Parameters	Units	Value	Reference/ Remarks
Type of Furnace		Box test Furnace	Shared by plant team during site visit
Rated Capacity of Furnace (for each burner)	kCal/hr	50,000	
Rated Capacity of Combustion Blower	HP	10	Name Plate
Rated Combustion Blower Flow	m ³ /Hr	1360	Shared by plant team
Rated Combustion Blower Head	inch wc	40	
Rated Capacity of Exhaust Blower	HP	5	Name Plate
Rated Exhaust Blower Flow (ENCON 40/5)	m ³ /hr	600	
Rated Exhaust Blower Head	inch water column	40	Shared by plant team during site visit
Unit Price of fuel	INR/Kg	46.58	
Unit Price of Electricity	INR/kWh	8.5	
Fuel details (CNG / NG / LPG)		LPG	
Fuel Density	Kg / Nm ³	1.96	
Fuel Calorific Value	kCal /Kg	11,000	
Furnace Dimension	Dia	1.490 metre	
	Length	6 metre	
	Thickness	150 mm	
Fuel to Air Ratio	Ratio	1:35	Ratio fixed by the plant team in the PLC
Average Furnace surface temperature	Deg C	75-100	Monitored during site visit
Ambient air temperature	°C	30	
Average Inlet combustion air temperature	°C	30	
Average Flue gas temperature, Inlet to ceramic media box	°C	564	

3. TECHNOLOGY MEASUREMENT AND VERIFICATION

The overall system was commissioned in the month of March and the final measurement & verification (M&V) studies were conducted by UNIDO (Mr K V Kiran Kumar) and CII-Godrej Green Business Centre (Mr Dinesh Ghai and Mr Nitish Kumar) team on 22nd June and 01st Sep, 2020. With reference to the first collected data, there was an online discussion with one of the expert panel members, Mr A K Asthana along with Mr Sandeep Tandon, NPM, on 29th August 2020, for seeking their guidance to complete the trials.



Figure 2 – Regenerative Burner System

A technology verification template has been designed to capture all the parameters during the M&V process and same has been shared to the ENCON. As per the template, during the M&V period gas totalizer along with PLC controller data values were used to monitor and analyse the parameters. The test furnace started at 7:00AM on 1st September 2020 and the furnace temperature was set at 910 °C. The furnace temperature got stabilised at around 10:30AM. After attaining the stable temperature key parameters captured with the help of PLC for every 10 sec and steady state values were used for the calculations. The data was recorded by varying the reversal cycle duration i.e. for 60 sec, 90 sec, 120 sec, 150 sec and 180 sec.

The data was recorded by connecting pen drive to the PLC system. To arrive at the optimum reversal cycle time, initially data for at least 2-4 batches/cycles was captured for each reversal cycle of the burner. After every reversal cycle, the data was transferred into excel sheet from the pen-drive by using the software. Later for at least 45 minutes data was collected by operating the furnace for each 90 sec & 120 sec reversal cycle to understand for further analysis. After collection of all readings, the furnace was switched off around 3:30 PM.

Some of the key parameters observed, monitored and analysed during the overall study were:

- Furnace Temperature, Combustion air, Inlet & Outlet temperature (across Ceramic media box)
- Flue gas, Inlet & Outlet temperature (across Ceramic media box)
- Fuel consumption (based on totalizer)
- Combustion Air flow. (based on Multiplication Factor 35)



Figure 3: Furnace with Regenerative Burners on either ends

Temperature probes in the air & flue gas path, instantaneous LPG gas flow meter in the LPG flow pipeline and Instantaneous air flow meter in the air flow duct were installed for the pilot study in the furnace. The data was continuously transferred from these instruments to the PLC for the monitoring & recording purpose.

4. FINDINGS

The system was tested at different duration of reversal cycles of burners and after achieving the steady, multiple batches of parameters were collected for analysis. The testing was conducted for 60, 90, 120, 150, and 180 seconds duration cycle to arrive at the optimum reversal cycle time, and initially data for at least 2-4 batches/cycles was captured for each reversal cycle of the burner. The major parameters monitored during each cycle are discussed below:

1. 60 second reversal cycle

Two sample batches for the duration of 60 seconds of burner reversal cycles were taken. In batch-1 burner A & B were in regenerative & firing mode respectively, and in batch-2 it was vice-versa. The detailed parameters captured during the study are given below:

Table 3: Sample Data Batch -1 & 2

Cycle time				60 Seconds			Batch-1			
S No.	Time	Burner mode		Temperatures (Deg C)						
	secs	Regenerative	Firing	Furnace	combustion air			Flue gas		
					inlet	outlet	ΔT	inlet	outlet	ΔT
1	10	A	B	913	30	424	394	532	82	450
2	20	A	B	895	30	413	383	548	83	465
3	30	A	B	894	30	389	359	560	84	476
4	40	A	B	873	30	391	361	560	83	477
5	50	A	B	889	30	435	405	537	82	455
6	60	A	B	913	30	484	454	520	80	440
Cycle time				60 Seconds			Batch-2			
S No.	Time	Burner mode		Temperatures (Deg C)						
	secs	Regenerative	Firing	Furnace	combustion air			Flue gas		
					inlet	outlet	ΔT	inlet	outlet	ΔT
1	10	B	A	920	30	536	506	478	65	413
2	20	B	A	896	30	531	501	494	66	428
3	30	B	A	910	30	514	484	518	68	450
4	40	B	A	907	30	505	475	526	70	456
5	50	B	A	887	30	507	477	526	69	457
6	60	B	A	883	30	526	496	477	67	410

The average of all the steady state parameters for batch 1 & 2 were taken, and for calculation purpose the average of batch 1 & 2 parameters were considered.

Table 4: Steady State Parameters at 60 Sec Cycle

Batch - 60 Sec Cycle	Average Steady state Temperatures (Deg C)							Fuel consumption (based on totalizer), Nm ³ /hr	Estimated Combustion Air flow, Nm ³ /hr
	Furnace	Combustion air			Flue gas				
		Inlet	Outlet	ΔT	Inlet	Outlet	ΔT		
Batch -1(A-Regen. and B -Firing)	896	30	423	393	543	82	461	7.33	256.55
Batch -2(A- Firing and B -Regen.)	901	30	520	490	503	68	436	6.39	223.77
Average of Batch 1 &2	898	30	471	441	523	75	448	6.86	240.16

Table 5: Heat Gain in 60 Sec Cycle

Calculations				Average	Reference / Annexure
Batch Number		1	2		
Heat Input from the fuel	kCal /hr	1,58,035	1,37,841	1,47,938	Page No 20
Heat Gained by Combustion air	kCal /hr	29,959	32,597	31,278	
Total Heat input to maintain constant furnace temperature	kCal /hr	1,87,994	1,70,437	1,79,216	
% Heat gained by Combustion air or potential Fuel savings	%	16%	19%	17%	
heat recovered from flue gas	kCal / hr	40,052	33,050	36,551	
WHR Effectiveness	%	75	99	87	

During the steady state condition, heat gain by the combustion air for batch 1 & 2 was found to be 16% and 19 % respectively and the WHR effectiveness was found to be 75% & 99%. Whereas average heat gain & WHR effectiveness of the overall system in this reversal cycle were 17% and 87% respectively.

Similarly, in the case of the 90, 120, 150- and 180-seconds reversal cycles multiple batches of data were taken to get the average steady values.

2. 90 second reversal cycle

Four batches for the duration of 90 seconds of burner reversal cycles, were taken and the major average steady state parameters monitored and observed during the studies were as follows:

Table 6: Steady State Parameters at 90 Sec Cycle

Batch - 90 Sec Cycle	Average Steady state Temperatures (Deg C)							Fuel consumption (based on totalizer), Nm ³ /hr	Estimated Combustion Air flow, Nm ³ /hr
	Furnace	Combustion air			Flue gas				
		Inlet	Outlet	ΔT	Inlet	Outlet	ΔT		
Batch -1(A-Regen. and B -Firing)	904	30	460	430	587	97	490	6.32	221.13
Batch -2(A- Firing and B -Regen.)	904	30	543	513	542	80	461	6.50	227.58
Batch -3(A-Regen. and B -Firing)	901	30	432	402	570	100	470	9.55	334.29
Batch -4(A- Firing and B -Regen.)	906	30	552	522	532	79	453	7.31	255.74
Average of all	904	30	497	467	558	89	469	7.42	259.69

The steady state heat gain by batch 1, 2, 3 & 4 was found to be 17%, 20%, 16% and 20 % respectively, whereas average heat gain & WHR effectiveness of the overall system in the cycle were 18% and 86%

Table 7: Heat Gain in 90 Sec Cycle

Calculations						Average
Batch Number		1	2	3	4	
Heat Input	kCal / hr	1,36,216	1,40,192	2,05,924	1,57,535	1,59,967
Heat Gained by Combustion air	kCal / hr	28,248	34,751	39,976	39,700	35,669
Total Heat	kCal / hr	1,64,464	1,74,942	2,45,900	1,97,235	1,95,635
% Heat gained by Combustion air or potential Fuel savings	%	17%	20%	16%	20%	18%
heat recovered from flue gas	kCal / hr	36,751	35,594	53,304	40,510	41,540
WHR Effectiveness	%	77	98	75	98	86

3. 120 second reversal cycle

Four batches for the duration of 120 seconds of burner reversal cycles were taken, and the major average steady state parameters monitored and observed during the studies were as follows:

Table 8: Steady State Parameters at 120 Sec Cycle

Batch - 120 Sec Cycle	Average Steady state Temperatures (Deg C)							Fuel consumption (based on totaliser), Nm ³ /hr	Estimated Combustion Air flow, Nm ³ /hr
	Furnace	Combustion air			Flue gas				
		Inlet	Outlet	ΔT	Inlet	Outlet	ΔT		
Batch -1(A-Regen. and B -Firing)	904	30	422	392	593	88	505	8.69	304.09
Batch -2(A- Firing and B -Regen.)	903	30	522	492	544	82	462	7.61	266.42
Batch -3(A-Regen. and B -Firing)	903	30	421	391	593	89	504	8.47	296.30
Batch -4(A- Firing and B -Regen.)	904	30	528	498	549	82	467	7.89	276.04
Average of all	904	30	473	443	570	85	484	8.16	285.71

The steady state heat gain by batch 1, 2,3 & 4 was found to be 16%, 19%, 16% & 19% respectively, whereas average heat gain & WHR effectiveness of the overall system in the cycle were 18% and 80%

Table 9: Heat Gain in 120 Sec Cycle

Calculations						Average
Batch Number		1	2	3	4	
Heat Input	kCal / hr	1,87,320	1,64,113	1,82,520	1,70,044	1,75,999
Heat Gained by Combustion air	kCal / hr	35,450	38,974	34,424	40,882	37,433
Total Heat	kCal / hr	2,22,770	2,03,087	2,16,945	2,10,926	2,13,432
% Heat gained by Combustion air or potential Fuel savings	%	16%	19%	16%	19%	18%
heat recovered from flue gas	kCal / hr	52,053	41,743	50,594	43,696	47,022
WHR Effectiveness	%	68	93	68	94	80

3. 150 second reversal cycle

Two batches for duration of 150 seconds of burner reversal cycles were taken, and the major average steady state parameters monitored and observed during the studies were as follows:

Table 10: Steady State Parameters at 150 Sec Cycle

Batch - 150 Sec Cycle	Average Steady state Temperatures (Deg C)						Fuel consumption (based on totalizer), Nm ³ /hr	Estimated Combustion Air flow, Nm ³ /hr	
	Furnace	Combustion air			Flue gas				
		Inlet	Outlet	ΔT	Inlet	Outlet			ΔT
Batch -1(A-Regen. and B -Firing)	905	30	538	508	556	83	473	6.93	242.64
Batch -2(A-Regen. and B -Firing)	904	30	404	374	611	108	503	8.82	308.80
Average of Batch 1 & 2	904	30	471	441	583	95	488	7.88	275.72

The steady state heat gain by batch 1 & 2 was found to be 20% and 15 % respectively, whereas the average heat gain & WHR effectiveness of the overall system in the cycle were 17% and 78%.

Table 11: Heat Gain in 150 Sec Cycle

Calculations				Average
Batch Number		1	2	
Heat Input	kCal / hr	1,49,468	1,90,221	1,69,845
Heat Gained by Combustion air	kCal / hr	36,633	34,383	35,508
Total Heat	kCal / hr	1,86,101	2,24,604	2,05,352
% Heat gained by Combustion air or potential Fuel savings	%	20%	15%	17%
heat recovered from flue gas	kCal / hr	38,904	52,708	45,806
WHR Effectiveness	%	94	65	78

5. 180 second reversal cycle

Two batches for the duration of 180 second of burner reversal cycles were taken, and the major average steady state parameters monitored and observed during the studies were as follows:

Batch - 180 Sec Cycle	Average Steady state Temperatures (Deg C)							Fuel consumption (based on totaliser), Nm ³ /hr	Estimated Combustion Air flow, Nm ³ /hr
	Furnace	Combustion air			Flue gas				
		Inlet	Outlet	ΔT	Inlet	Outlet	ΔT		
Batch -1(A-Regen. and B - Firing)	904	30	427	397	582	91	491	7.22	252.82
Batch -2(A-Regen. and B - Firing)	900	30	406	376	589	85	504	10.13	354.62
Average of Batch 1 & 2	902	30	416	386	585	88	497	8.68	303.72

The steady state heat gain by batch 1 & 2 was found to be 16% and 15 % respectively, whereas average heat gain & WHR effectiveness of the overall system in the cycle were 16% and 68%.

Calculations				Average
Batch Number		1	2	
Heat Input	kCal / hr	1,55,737	2,18,446	1,87,091
Heat Gained by Combustion air	kCal / hr	29,861	39,624	34,743
Total Heat	kCal / hr	1,85,598	2,58,070	2,21,834
% Heat gained by Combustion air or potential Fuel savings	%	16%	15%	16%
heat recovered from flue gas	kCal / hr	42,070	60,572	51,321
WHR Effectiveness	%	71	65	68

The average furnace temp. was 904^oC and flue gas inlet.558^oC and 89^o C outlet. The gap between furnace and flue gas temp. was 346^oC. In absence of any heat transfer media this much temp. drop is not possible in a furnace fitted with regenerative burner. Normally the difference should not be more than 150^oC if the furnace temp is less than 1000^oC. This could be due to improper positioning of thermocouple due to limited combustion volume. But this will not affect the performance of the burner.

5. CONCLUSION AND REPLICATION POTENTIAL

The summary of results for all the 60, 90, 120, 150, and 180 seconds cycles are given below:

Table 12: Summary of Results

Cycle Time, Seconds		60 Sec	90 Sec	120 Sec	150 Sec	180 Sec	Average
Combustion air Temperature, °C	Inlet	30	30	30	30	30	30
	Outlet	471	497	473	471	416	466
	ΔT	441	467	443	441	386	436
Flue gas Temperature, °C	Inlet	523	558	570	583	585	564
	Outlet	75	89	85	95	88	87
	ΔT	448	469	484	488	497	477
Fuel consumption	m ³ /hr	6.86	7.42	8.16	7.88	8.68	7.8
Combustion air flow	m ³ /hr	240.16	259.69	285.71	275.72	303.72	273
Heat Input	kCal / hr	1,47,938	1,59,967	1,75,999	1,69,845	1,87,091	1,68,168
Heat Gained by Combustion air	kCal / hr	31,278	35,669	37,433	35,508	34,743	34,926
% Heat Gained by Combustion air/Fuel Savings	%	17.45%	18.23%	17.54%	17.29%	15.66%	17.24%
Heat recovered from flue gas	kcal / hr	36,551	41,229	47,022	45,806	51,321	44,386
WHR Effectiveness	%	87	86	80	78	68	79

Table 13: Savings for 50,000 kcal / hr furnace

Parameters	Units	Value
Rated Capacity of Furnace	kCal/Hr	50,000
Percentage Fuel Saving	%	18.23%
Fuel consumption per hour	kg/hr	15.29
Fuel Saving per hour	kg/hr	2.79
Fuel GCV	kcal / kg	11,000
Energy saving	TOE / hr	0.0031
Emission factor	kg CO ₂ / kg fuel	2.9800
GHG Reduction per Hour	kg CO ₂ /hr	8.31

The monitoring and verification study conducted by CII- GBC and UNIDO team members at Encon Thermal Engineers for newly installed Regenerative Burners in the furnace to assess the performance of waste heat recovery device. Different reversal cycle trails (60, 90, 120, 150, 180 seconds) were conducted to ascertain the best heat recovery performance of the system, it was observed, the waste heat recovery effectiveness is 86 % when the reversal time is 90 seconds. (Reversal cycle means that the weight of silica balls in each burner attains heat saturation in 90 seconds).



Figure 4 Plaque on Furnace with Regenerative Burners

The measured average operating parameters during the course of study **for optimum reversal time of 90 secs** are as follows:

- Furnace temperature at steady state 902°C
- Flue gas temperature inlet to regenerator 558°C
- Flue gas temperature outlet of chimney 89°C
- Drop in flue gas temperature 469°C
- Inlet combustion air temperature 30°C
- Combustion air preheated temperature 497°C
- Increase combustion air temperature 467°C
- Waste heat recovery effectiveness 86%
- Fuel savings 18.23%

Fuel and GHG savings for a furnace with 50,000 kcal capacity were 2.79 kg of LPG /hr and 8.31 kg CO₂ /hr.

On the basis of above operating parameters of Regenerative Burner performance, following are our key observations for computation of fuel savings:

- a. Regenerative Burners are mostly installed in high temperature furnaces for reheating and melting application. For high flue gas temperature metallic recuperator is not used.

- b. The flame temperature is around 1,400-1,500°C, when combustion air temperature is 30°C, the flame temperature increases to around 2,000°C if combustion air preheated to 500°C.
- c. In high temperature furnaces the mode of heat transfer is through radiation (95%) which is function of the fourth power of Temperature or $(T)^4$. An increase in radiation heat transfer results higher fuel savings which would be accrued due to less excess air for combustion, reduce cold start up time, increase in production capacity of furnace and uniform temperature distribution across furnace.

All the above factors could not be established in the absence of base line assessment, it is expected that fuel savings would be much more than 18.23% as reported in M&V report.

Replication Potential

The replication potential of the technology is very high, there are more than 10,000 different types of furnaces running across different industries (Aluminium melting, Steel Reheating, Forging Furnaces, Heat treatment furnaces) in India of different sizes and fuel. Regenerative burner system can potentially retrofit all these furnaces and each furnace will require at least 1 set of these burner.

The anticipated replication potential across various sectors is given below in the table:

Table 134: Anticipated replication potential across different sectors

Sector	Number of units in the country	Type of Furnace / Kiln	Kiln / furnace capacity (Reference)	Furnace temperature, Deg C	Exhaust gas temperature available for (recovery) Deg C	Fuel saving possible	Annual fuel saving for reference plant*	Replication potential		Annual Cost savings (INR Million)	Annual GHG emission reduction possible (MT CO ₂)
			Values for a typical Reference unit			%	GWh - Thermal	%	Number of units	Total Replication potential	Total Replication potential
Steel - ISP, SIP	163	Reheating furnace/Blast furnace hot stove/ LADLE Preheaters/Soaking Pits	100 - 300 TPH	1150 -1300	500- 1000	20-30	4.32	20	32	446.08	25,611
Steel Re Rolling	1800	Reheating Furnace	8 - 320 TPH (Billets - Input)	1200	800 - 900	25-30	0.75	10	180	435.60	25,011
Aluminium (Recycled /secondary)	3500	Melting / Holding furnace	3000 kW -25000 kW	1300 -1400; 700 - 800	800 - 900; 600 -700	20-30	1.8	10	350	2033.5	1,16,717
Forging	400	Forging Furnace	1 - 150 TPH	900-1350	500-650	5-40	0.15	20	80	38.40	2,223
Glass	200	Glass furnace		1400-1700	450-600	10-30	2.88	10	20	186.00	10,671
Total	6,063						9.90		662	3,140	1,80,233

* Assuming Natural Gas will be used as a fuel in the furnaces with Gross Calorific Value of 12,500 kcal/kg of fuel and the CO₂ emission factor at 2.69 kg of CO₂/kg of fuel

Considering the adoption of the technology in 662 units (10.9%) out of 6,063 units in above mentioned sectors; the annual monetary saving of INR 3,140 Million can be anticipated, with an overall GHG reduction potential of 1,80,233 MT CO₂.

Disclaimer: Benefits estimated by CII-GBC based on data gathered from field trials. Since this solution/product is not yet commercially available, the ROI has not been estimated.

6. ANNEXURE

ANNEXURE A : ASSUMPTIONS MADE IN THE REPORT

The following assumptions were made while preparing the report:

- Calorific value of fuel (LPG)- 11,000 kCal/kg;
- Grid electricity- 860 kCal/kW.
- Gas to Air ratio was Set as 1:35, for every 1Nm³ of LPG, 35Nm³ of Air was supplied
- Specific heat of flue gas; $c_p = 0.23$ kcal/kg/°C and
- density of flue gas = 1.293kg/m³ @900 Deg. Celsius
- CO₂ emission factor of LPG fuel : 2.98 kg CO₂ /kg of LPG
- Combustion air temperature at inlet : 30 Deg. Celsius

ANNEXURE B : MAJOR FORMULAE USED IN THE REPORT


The following formulae were used while preparing the report:

1. Combustion Air flow, Nm³/hr
= Fuel consumption (Nm³/hr) x 35 (Theoretical air requirement)
2. Heat Input to the furnace, kCal/hr
= Fuel consumption (kg/hr) x Calorific value of fuel (kCal/kg)
3. Heat Gained by Combustion air, kCal/hr
= Flowrate of flue gas (Nm³/hr) x Density of flue gas (kg/m³) x Specific heat of flue gas(c_p) x difference in inlet-outlet temperature (ΔT)
4. Total Heat, kCal/hr
= Heat Input to the furnace + Heat Gained by Combustion air
5. % Heat Gained by Combustion air or potential Fuel savings, %
= (Heat Gained by Combustion air/ Total Heat) x 100


ANNEXURE C : REFERNCES & REPORTS REFERRED FOR ESTIMATING REPLICATION POTENTIAL

1. PAT document /notifications from PAT cycle 2 – 6
2. <http://srma.co.in/home.html>
3. <https://www.alcircle.com/news/asma-files-a-petition-in-the-commerce-ministry-against-hiking-import-duty-on-aluminium-and-scrap-40860>,<https://www.metalbulletin.com/events/download.ashx/document/speaker/6563/a0ID000000X0jaoMAB/Presentation> , page 56, ESEL, JICA SIDBI 9.1
4. <https://www.jamnagarfactoryassociation.com/about.php>, BOP - BEE best practices
5. <https://www.jamnagarfactoryassociation.com/about.php>, BOP - BEE best practice

ANNEXURE D : P&I DIAGRAM OF THE EXISTING SETUP



ANNEXURE E : BLOCK DIAGRAM CONSIDERING 90 SEC REVERSAL CYCLE FOR MODE A & MODE B



Note: Four batches of 90 seconds reversal cycle data were taken; Batch 1 & 3 were in mode B, whereas batch 2 & 4 were in mode A. Average values are shown in the block diagram for mode B and A.

ANNEXURE F : P&I DIAGRAM MULTI BORE ORIFICE PLATE ASSEMBLY

FILE NAME--48017 ENCON

NOTES:-

- ORIFICE PLATE DESIGNED AS PER ISO-5167
- BORE TOLERANCES AS PER ISA-RP-3.2
- TAPPING : FLANGE TAPS 1 Pair
- FLANGE FACING AS PER ANSI B16.5 150#(SORF)
- ALL DIMENSIONS IN M.M. UNLESS OTHERWISE STATED.
- ALL UNSPECIFIED TOLERANCE ± 2 M.M.
- TAG NO., BORE DIA, AND FLOW DIR., WILL BE PUNCHED ON THE ORIFICE PLATE. NB SIZE, TAG NO, RATING & MOC SHALL BE PUNCHED ON THE FLANGE.

TAG NO	SERVICE	PIPE O.D.	PIPE I.D. D	N.B. SIZE	QTY.
FE-1	LPG	48.3	40.9	40	1
FE-2	AIR	168.3	154.08	150	1

O.D. O	THK M ± 0.5	Calc. Bore	NO. OF HOLES	BORE d1	PCD P
82	3.2	16.88	4	8.44 ± 0.04	26
219	3.2	103.54	4	51.77 ± 0.04	96

NO.	DESCRIPTION	QUANTITY (PER ASSY.)	MATERIAL
1.	FLANGES (SORF.)	2	ASTM A105 (Not in Espl's scope)
2.	ORIFICE PLATE	1	S.S.-316
3.	GASKETS	2	NON ASBESTOS FIBRE (Not in Espl's scope)
4.	FASTENERS	As Reqd.	CARBON STEEL (Not in Espl's scope)
5.	JACK SCREW	2	CARBON STEEL (Not in Espl's scope)

ENGINEERING SPECIALITIES (PVT.) LTD.
 30 F, FREE SCHOOL STREET KOLKATA 700016
 Tel : (033) 2252 2064, 2252 5584 , e-mail: contact@espl.co.in

Client : ENCON THERMAL ENGINEERS PVT. LTD. Project :

Subject : MULTI-BORE ORIFICE PLATE ASSEMBLY

Drn.	P.B.	24.09.2019	DRG. NO.	scale	Rev.1 04.03.20
Ckd.	D.P.	24.09.2019	ESC-48017	N.T.S.	Sheet 1 of 1
Appvd.					

ANNEXURE G : ORIFICE PLATE BORE CALCULATION AS PER ISO-5167 FOR AIR

Date : 04-03-2020

PREP BY : DP

ORIFICE PLATE BORE CALCULATION AS PER ISO-5167

(Prog. By Engineering Specialities Pvt Ltd., Kolkata 700016, Ph : 33-2252-5584/2064, email : contact@espl.co.in)

CLIENT	ENCON THERMAL ENGINEERS PVT.LTD.	PO# 338 of 24/09/2020
PROJECT		
NB SIZE	150 mm NB Sch. 40	Rev. No. : 1 - 04032020
TAG NO.	FE-2	Quantity : 1 No.
SERVICE	AIR	FLANGE TAPS

PIPING DATA	PIPE SIZE & SCH	:	150 mm NB Sch. 40
	PIPE MATERIAL	:	CARBON STEEL
	FLANGE STANDARD	:	ANSI-B16.5 150# SORF
	FLANGE MATERIAL	:	ASTM-A105

FLOW DATA

Std.Pipe ID(at 20°C)	=	0.15408	M	=	154.08	mm
Temp. Corr. For I.D.	=	1.00017				
D	Corrected I.D.	=	0.154105	M		
T	Operating Temperature	=	35	deg. C		
BP	Barometric Pressure	=	100000	Pa	=	1 Bar
Pr	Line Pressure	=	9715	Pa	=	97.145 mBar (g) = 39 "WC
Op	Operating Pressure	=	109715	Pa	=	1.10 Bar (a)
v	Dynamic Viscosity	=	0.000017	Pa.s	=	0.00017 Poise
G	Specific Gravity	=	1		=	1.293 Kg/NcM
p	Density Oper. Cond.	=	1.24104	Kg/cm		
Qn	Volumetric Flow	=	1250	NcM/Hr		
Qv	Actual Vol. Flow	=	0.361760	cM/sec	=	1302.34 cM/Hr
Qm	Mass Flow	=	0.448958	Kg/sec	=	1616.25 Kg/hr
h	Differential Press.	=	2500	Pa	=	25 mBar

SIZING CRITERIA

ReD	Reynold's Number at 70% flow	=	152738.1
k	Isentropic Exponent	=	1.4
e	Expansibility Factor	=	0.992172
E	Velocity of Approach Factor	=	1.120862
B	d/D (Beta) Ratio	=	0.672086
C	Discharge Coefficient	=	0.608296
	Temp. corr. For Bore	=	1.00027

ELEMENT DATA

ELEMENT TYPE	:	MULTI-BORE ORIFICE PLATE
ELEMENT MOUNTING	:	FLANGED
ELEMENT MATERIAL	:	SS-316
ORIFICE BORE	:	0.103544 M
ORIFICE BORE (Corr.)	:	0.103544 M = 103.54 mm
TOLERANCE AS PER ISA	:	+/- 0.05 mm
PLATE THICKNESS	:	3.2 mm
THROAT THICKNESS(t)	:	3.2 mm

NOTES :

PERMANENT PRESSURE LOSS AT MAXIMUM FLOW :	13.2 mBar =	52.9 % of DP
ERROR IN CALCULATION :	0.00008 %	
FLOW CHECK =	0.449 Kg/sec	
MULTI-BORE ORIFICE PLATE :	NOS. OF HOLES - 4 NOS.	HOLE SIZE : 51.77 mm φ
MAXIMUM FLOW :	500 NcM/hr	DP AT MAXIMUM FLOW : 4.0 mBar

d/Xcalc/misc/Encon-lpg air op 19092019

ANNEXURE H : ORIFICE PLATE BORE CALCULATION AS PER ISO-5167 FOR LPG

Date : 19-09-2019

PREP BY : DP

ORIFICE PLATE BORE CALCULATION AS PER ISO-5167

(Prog. By Engineering Specialities Pvt Ltd., Kolkata 700016, Ph : 33-2252-5584/2064, email : contact@espl.co.in)

CLIENT	ENCON THERMAL ENGINEERS PVT.LTD.		
PROJECT			
NB SIZE	40 mm NB Sch. 40	Rev. No. :	0
TAG NO.	FE-1	Quantity :	1 No.
SERVICE	LPG GAS	FLANGE	TAPS

PIPING DATA	PIPE SIZE & SCH	:	40 mm NB Sch. 40
	PIPE MATERIAL	:	CARBON STEEL
	FLANGE STANDARD	:	ANSI-B16.5 150# SORF
	FLANGE MATERIAL	:	ASTM-A105

FLOW DATA					
	Std. Pipe ID(at 20°C)	=	0.0409	M	= 40.9 mm
	Temp. Corr. For I.D.	=	1.00017		
D	Corrected I.D.	=	0.040907	M	
T	Operating Temperature	=	35	deg. C	
BP	Barometric Pressure	=	100000	Pa	= 1 Bar
Pr	Line Pressure	=	15000	Pa	= 150 mBar (g)
Op	Operating Pressure	=	115000	Pa	= 1.15 Bar (a)
v	Dynamic Viscosity	=	0.000017	Pa.s	= 0.00017 Poise
G	Specific Gravity	=	1.516		= 1.960 Kg/NcM
p	Density Oper. Cond.	=	1.97205	Kg/cM	
Qn	Volumetric Flow	=	25	NcM/Hr	
Qv	Actual Vol. Flow	=	0.006903	cM/sec	= 24.85 cM/Hr
Qm	Mass Flow	=	0.013612	Kg/sec	= 49.0047 Kg/hr
h	Differential Press.	=	2500	Pa	= 25 mBar

SIZING CRITERIA		
ReD	Reynold's Number at 70% flow	= 17446.1
k	Isentropic Exponent	= 1.4
e	Expansibility Factor	= 0.993477
E	Velocity of Approach Factor	= 1.014828
B	d/D (Beta) Ratio	= 0.412702
C	Discharge Coefficient	= 0.607418
	Temp. corr. For Bore	= 1.00027

ELEMENT DATA		
ELEMENT TYPE	:	MULTI-BORE ORIFICE PLATE
ELEMENT MOUNTING	:	FLANGED
ELEMENT MATERIAL	:	SS-316
ORIFICE BORE	:	<u>0.016878</u> M
ORIFICE BORE (Corr.)	:	<u>0.016878</u> M = 16.88 mm
TOLERANCE AS PER ISA	:	+/- 0.01 mm
PLATE THICKNESS	:	3.2 mm
THROAT THICKNESS(t)	:	3.2 mm

NOTES :

PERMANENT PRESSURE LOSS AT MAXIMUM FLOW : 20.2 mBar = 81.0 % of DP
 ERROR IN CALCULATION : 0.00010 %
 FLOW CHECK = 0.014 Kg/sec
MULTI-BORE ORIFICE PLATE : NOS. OF HOLES - 4 NOS. HOLE SIZE : 8.44 mm φ
 MAXIMUM FLOW : 500 NcM/hr DP AT MAXIMUM FLOW : 10000.0 mBar

d/Xcalc/misc/Encon-lpg air op 19092019

Facility for Low Carbon Technology Deployment BEE UNIDO GEF Initiative

Waste Heat Recovery Innovation Challenge 2019

The **Facility for Low Carbon Technology Deployment (FLCTD)** project, implemented by the United Nations Industrial Development Organization (UNIDO) in collaboration with the Bureau of Energy Efficiency (BEE) is launching the 2019 Innovation challenge in Waste Heat Recovery (WHR) technology vertical.

In the annual challenge concluded in 2018, 3 winning innovations were selected for technology demonstration in the WHR vertical. The total award money committed for the winners is INR 85,97,000 (US\$122,814). The list of winners of FLCTD Innovation Challenge 2018 is available here: <https://low-carbon-innovation.org/2018-winners>

Entries are invited to the 2019 FLCTD Innovation Challenge for Waste Heat Recovery to identify the promising innovations in the areas described below, which can be deployed to address technology gaps and improve energy efficiency. The total award money earmarked for this particular technology vertical for 2019 Annual Innovation Challenge is US \$400,000.

The Challenge is open for Waste Heat Recovery technology innovations across all industrial sectors for the following:

- **High temperature range**– Innovations demonstrating heat recovery at temperature ranges above 600 degree Celsius for productive end-use applications such as, but not limited to, power generation, pre-heating of feedstock, pre-heating of primary / secondary air, space conditioning or any other use in the process or utility service that requires heating. The innovation should demonstrate reduction in the energy released in atmosphere from the production processes that are either continuous or intermittent (batch process) type, without effecting product quality.
- **Medium temperature range**– Innovations demonstrating heat recovery at temperature ranges between 600 degree and 150 degree Celsius for productive end-use applications such as, but not limited to, power generation, pre-heating of feedstock, pre-heating of primary / secondary air, moisture removal from feedstock or solid fuel, space conditioning or any other use in the process or utility service that requires heating. The innovation

should demonstrate reduction in the energy released in atmosphere from the production processes that are either continuous or intermittent (batch process) type, without effecting product quality.

- **Low temperature range** – Innovations demonstrating heat recovery at temperature range below 150 degree Celsius for productive end applications such as, but not limited to, pre-heating of feedstock, moisture removal from solid fuel, cooling or any other use in the process or utility service that utilizes heat. The innovation should demonstrate reduction in the energy released in atmosphere from the production processes that are either continuous or intermittent (batch process) type.

All innovative solutions should be based on the proof-of-concept or early stage prototype and clearly indicate the replication potential and opportunities for scale-up, and also the following:

- ✓ Innovations that result in overall efficiency improvements
- ✓ Emerging and novel technology applications that reduces energy consumption, including through power generation, system heat requirement reduction, etc.
- ✓ Design improvements that reduce energy consumption, overcome application constraints and improve economic feasibility
- ✓ Heat recovery from untapped/un-utilized sources of heat
- ✓ Fossil fuel reduction in applications or integration of renewable energy.

Eligibility

- The innovation challenge is open to Entrepreneurs, Startups, Indian Technical Institutes / Universities, Research Institutes, Micro, Small and Medium Enterprises, Industries, Public Sector Enterprises and Government Laboratories.
- Consortiums of entrepreneurs and academic institutions with industry partnerships are highly encouraged to participate in the innovation challenge.
- Innovation teams with **women entrepreneurs** will be given preference.

Incentives for Participation

- **Grant** up to USD 50,000 for winning technology with provision for demonstration at multiple locations, wherever required;
- **Performance Verification** to establish the efficacy of innovative technology in-field working conditions;
- **Business Acceleration and Mentoring** support from industry experts;

- Opportunity to **Network** with investors and industry stakeholders to publicize the innovation;
- The winners of the Innovation Challenge will receive recognition from Bureau of Energy Efficiency and UNIDO;
- Grant disbursement will be linked to specific progress-based milestones
 - 30% of the award grant will be given to the innovator winning the innovation challenge
 - 50% after installation/commissioning of the innovation
 - 20% at the end of the deployment phase, upon completion of Technology Verification Reporting

Parameters for Selection

This is only an indicative list, and is not exhaustive, and is subject to change and modification.

- Nature of innovation (Product design/Process Innovation)
- Addresses a key issue/technology gap in the industry
- Replication potential
- Scalability and sustainability
- Energy saving and greenhouse gas emission reduction potential
- Financials (pay-back period, Internal Rate of Return)
- Technology readiness stage (R&D/ Prototype/Pilot demonstration/Commercial)
- Intellectual Property Right / Patents (granted/applied)

General Guidelines, Terms, and Conditions

- Participant shall submit solutions/product designs owned by them or to which they have right to claim and use as owned by them. Suitable documents to this effect must be submitted along with the entry.
- Participant shall ensure that any submission made in the Challenge does not violate any of theirs or any third party's intellectual property rights, confidentiality, trade secret and violate any statutory provisions.
- BEE, UNIDO, its employees, members of Expert Panel and organizers of this innovation challenge shall in no event be liable for any violation of IPR, or license or permits required from third party.
- Participant shall not assign any rights, obligations, or privileges hereunder without the prior written consent of Organizers of the Challenge.
- BEE, UNIDO, Organizers, members of Expert Panel, supporting organizations or any employee or agent shall not be liable for, any costs incurred or loss or liability or loss in expectation of profits or loss due to failure of understanding the terms and conditions of

the Challenge or of any expected benefit of the participant in relation to entry and submission in the Challenge.

- By way of selecting the entries for evaluation at any Stage or for Final Award, Participants shall not be entitled to claim or have got endorsement from BEE and UNIDO of any sought whatsoever, or have earned approval of any sought whatsoever of BEE and UNIDO, for use in any form whatsoever anywhere in the Industry.
- At any Stage while evaluating the entries, organizers shall be free to contact the Participants and carry out discussions on the matter submitted by the Participants and seek clarifications. Any solicitation by participants in whatever form in respect of their entries shall not be entertained and entries of such participant shall be disqualified from the Innovation Challenge.
- BEE/UNIDO/Organizers may change the Terms and Conditions of participation at any time without prior notice. It shall be sole responsibility of the Participants to update themselves of information posted in the website from time to time.
- BEE/UNIDO/Organizers may disqualify a Participants from the Challenge for breach of any of the conditions of this Challenge or discontinue this Challenge.
